

NEW APPLICATION

ORIGINAL



0000094519

COMMISSIONERS

RECEIVED

Kristin K. Mayes – Chairman
Gary Pierce
Paul Newman
Sandra Kennedy
Bob Stump

2009 MAR 12 P 3:45

AZ CORP COMMISSION
DOCKET CONTROL

Arizona Corporation Commission

DOCKETED

MAR 12 2009

DOCKETED BY

nr

BEFORE THE ARIZONA CORPORATION COMMISSION

W-01445A-09-0111

IN THE MATTER OF THE FILING BY
ARIZONA WATER COMPANY OF
REVISED TARIFF NO. CC-258, CROSS-
CONNECTION OR BACKFLOW TARIFF

DOCKET NO. W-01445A-09-_____

APPLICATION FOR A REVISED CROSS-
CONNECTION OR BACKFLOW TARIFF
NO. CC-258

Arizona Water Company, an Arizona public service corporation, (the "Company") pursuant to the provisions of A.R.S. §40-367, tenders for filing with the Commission its revised Tariff No. CC-258, Cross-Connection or Backflow Tariff. As required by A.R.S. §40-367.D, changes to currently effective Tariff No. CC-258 are indicated by marks on the revised tariff.

The purpose of this tariff is to protect the Company's water supply from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises.

The Company respectfully submits that revised Tariff No. CC-258 is in the public interest, and requests that revised Tariff No. CC-258 be approved to become effective thirty (30) days following the date of this filing.

IT IS HEREBY CERTIFIED that on March 12, 2009 Arizona Water Company tendered for filing in the Commission's Docket Control Division an original and ten (10)

1 copies of its revised Tariff No. CC-258 showing an effective date of thirty (30) days after the
2 date of initial filing with the Commission, all in accordance with A.R.S. §40-367.

3
4 RESPECTFULLY SUBMITTED this 24 day of March 2009.

5 ARIZONA WATER COMPANY

6
7 By:



8 Robert W. Geake

9 Vice President and General Counsel

10 ARIZONA WATER COMPANY

11 Post Office Box 29006

12 Phoenix, Arizona 85038-9006
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

TARIFF SCHEDULE

ARIZONA WATER COMPANY		A.C.C. No.	490434
Phoenix, Arizona		Cancelling A.C.C. No.	434None
Filed by:	William M. GarfieldR. E. Polenske	Tariff or Schedule No.	CC-258
Title:	President	Filed:	11-26-91
Date of Original Filing:	11-26-91-	Effective:	April 13, 2009November 26, 1991
System:	ALL SERVICE AREAS		

CROSS-CONNECTION OR BACKFLOW TARIFF CONTROL

APPLICABILITY:

All customers served by Arizona Water Company (the "Company").:-

PURPOSE:

The purpose of this tariff is to ~~to~~ protect the public water supply in each of Arizona Water Company's water systems from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises through unprotected cross-connections by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C."), R14-2-405.B.6 and A.A.C. R18-4-215, and any subsequent revisions to such codes applicable to the subject of this tariff., Title 14, Chapter 2, Section 405.B.6 as adopted by the Arizona Corporation Commission, and Title 18, Chapter 4, Section 232, as adopted by the Arizona Department of Environmental Quality.

INSPECTIONS:

The customer shall cooperate fully with ~~Arizona Water the~~ Company in its efforts to investigate and determine the degree of potential health hazard to the public water supply which may result from conditions existing on the customer's premises.

REQUIREMENTS:

In compliance with the Rules and Regulations of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality (ADEQ), specifically A.A.C. R14-2-405.B.6 and A.A.C. ~~R18-4-215~~R18-4-232 relating to backflow prevention:

1. ~~The~~Arizona Water Company may require a customer to pay for and ~~have installed~~install, maintain, test and repair a backflow-prevention assembly if A.A.C. R18-4-215.BR18-4-232.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.DR18-4-232.D and E.
3. ~~Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff.~~
4. ~~The~~Arizona Water Company shall give any ~~existing~~ customer who is required to install and/or test a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days in which to comply with this notice. If the customer can show good cause as to why he cannot install the ~~backflow-prevention assembly device~~ within thirty (30) days, ~~the~~ Arizona Water Company or the Arizona Corporation Commission Staff may ~~suspend~~ grant additional time for this requirement for a reasonable period of time.;
5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F.R18-4-232.F. ~~The~~Arizona Water Company ~~may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does~~ shall not require an unreasonable number of tests.
6. ~~5.~~The customer shall provide ~~the~~Arizona Water Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location;

- c. date(s) of test(s);
- d. description of repairs and recommendations for repairs made by tester; and
- e. the tester's name and certificate number.

7. DISCONTINUANCE OF SERVICE:

~~— In accordance with A.A.C. R14-2-407 and 410 and provisions of this tariff, Arizona Water Company may terminate service or deny service to a customer who fails to install and/or test a backflow prevention assembly as required by this tariff.~~

- A. In the event the backflow-prevention assembly ~~does~~has not ~~function properly~~been installed or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the is applicable, Arizona Water Company may terminate service immediately and without notice.- The backflow-prevention assembly shall be installed and repaired or replaced by the customer and retested, ~~before service is restored.~~

8.

- B. In the event the backflow-prevention assembly ~~does~~has not ~~function properly~~been installed or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be installed and/or repaired or replacedby the customer and retested within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function.~~written notice by Arizona Water Company. Failure to install or to remedy the deficiency or dysfunction~~disfunction of the assembly, or failure to retest, shall be grounds for termination of water utility service in accordance with A.A.C. R14-2-410.